BROMINE POOL LOG SHEET

Facility Name:):				
Week Beginning Monday,	, 20	Wading Pool Spa			
Total alkalinity must be recorded at least once a week . Date: Total alkalinity range 50-180 ppm Pool super chlorinated as needed. Date: Spa drained weekly . Date: Filters Backwashed. Date:	PPM:				
Main drains must be clearly visible at all times when the pool is open.					

	MON	TUE	WED	THUR	FRI	SAT	SUN
Test Pool	Br						
Water	pH						
Before	Time						
Opening	Initials						
CHEMICALS							
Required	FLOW						
Br levels	TEMP WATER						
2.0-2.5 ppm	CLEAR						
Spa	CLOUDY						
2.0-3.0 ppm	TURBID						
Minimum	Br						
4 Tests	pH						
Per Day	Time						
Required	Initials						
	Br						
	pH	pH	рН	pH	pH	pH	рН
	Time						
	Initials						
Maintain	Br						
pН	pH						
7.2-7.8	Time						
	Initials						

Louisville Metro Department of Public Health and Wellness Division of Environmental Health and Protection 400 East Gray Street, 2nd Floor Louisville, KY 40202

502-574-6650